

Suitability of fire extinguishers:



- Powder
- Foam
- Water



Powder extinguisher with ABC powder Water and foam extinguisher

Fires involving solid materials, mainly of an organic nature, which normally form flames and embers on burning



- Powder
- Foam
- CO₂



Powder extinguisher with BC and ABC powder Foam extinguisher CO₂ extinguisher

Fires involving liquids or melting materials



- Powder



Powder extinguisher with BC and ABC powder

Fires involving gases (e.g. propane, butane etc.)



- Powder



Powder extinguisher with D powder

Fires involving metals (e.g. magnesium, aluminum swarf)



- Foam



Fires involving fat and oil, extinguisher marked orange

At least one fire extinguisher conformant with DIN EN 3 with at least 12 extinguishing agent units (EAUs) must be kept on hand during assembly and disassembly and during the event itself at trade fair stands and event spaces larger than 100 m² and in case of electrical distribution boxes with a total power rating of 6 kW.

- The fire classes of fire extinguishers **have nothing** in common with the classification of building products to DIN 4102 and DIN EN 13501.
- The fire classes define **the suitability** of fire extinguishers for fires involving various materials, liquids or vapours that have caught fire.

Extinguishing agent		Fire classes				
Former Code letter		A	B	C	D	F
Water or Aqueous solutions	W		1		2	3
Water mist	W				2	
Foam	S				2	3
BC powder	P					
ABC powder	PG					
Metal fire powder	PM					
Carbon dioxide CO ₂	K				2	
Cooking oil/fat fire extinguisher agent	F		4		2	

● suitable ; ● not suitable

1: Risk of fire spreading

2: Risk of an explosive reaction

3: Risk of an cooking oil /fat explosion

4: Suitable for cooking oil/fat extinguishers of class A B F

Example of specified labeling to DIN EN 3:

FEUERLÖSCHER

12 Kg ABC-Pulver

43 A 183 B C

1 Ventil voll aufdrehen

2 Löschpistole betätigen

VORSICHT BEI ELEKTRISCHEN ANLAGEN. NUR BIS 1000 V; MINDESTABSTAND 1m

Nach jeder Betätigung neu füllen!
Löcher längstens alle 2 Jahre auf Einsatzbereitschaft überprüfen. Nur solche Lösch-Treibmittel und Ersatzteile verwenden, die mit dem anerkannten Muster übereinstimmen.

Löschmittel: 12 kg ABC Nr. der Anerkennung: DIN EN 3
 Treibmittel: 280 g CO₂ Typ: G 12 R

Funktionsbereich: -20 °C bis +60 °C

HERSTELLER: _____

Only water extinguishers or foam extinguishers with an up-to-date test seal may be used. Powder extinguishers may only be used for demonstrations with combustible gases. Cleaning costs resulting from the use of powder extinguishers will be charged to the perpetrator.

Generally, all fire extinguishers provided must have been tested by an accredited expert. This must be shown on the fire extinguisher itself by means of a valid test label or tag. All fire extinguishers must be placed in clearly visible and continuously accessible locations in such a way that they cannot topple over and must be labeled in accordance with ASR A1.3.